

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No: 7150-0796:103 Page 1 of 1

CATEGORY: Boxes/Pull Stations

LISTEE: Spectronics, 4645 Hartley St., Lincoln NE 68504
Contact: Bruce Steyer (402) 467-3651

DESIGN: Model SG-32AXK1, -K2, SG-32BK1, -K2, SG-32PSK, SG-32SK1, -K2 noncoded manual pull stations. Models have suffix 1 indicating push bar type and suffix 2 indicating no push bar. Suitable for outdoor use when installed with Model SGB-32C back boxes and for indoor when installed with Model SGB-32S back box. Refer to listee's data sheet for additional detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions applicable codes and ordinances and in manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as manual pull stations for use with separately listed and compatible fire alarm control units.

XLF: 7150-1408:107



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 11, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND, Senior Deputy**
Program Manager